

Annexure C


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 3310

Dated: 4/07/2024

It is certified that an inspection team headed by **Sh. Ashok Kumar, SUB DIVISION ENGINEER** from **PUBLIC HEALTH ENGG. SUB DIVISION No. 3 NARNAUL** inspected the **SUNRISE SR. SEC. SCHOOL, SALOONI TEHSIL – NARNAUL DISTT – M/GARH HR.** on **19-04-2024** and on the basis of Water Test Report (Attached) bearing no **PHEL/NNL/381** dated **26-04-2024** of **Water Testing Laboratory , Public Health Engg. Division No.1 Narnaul** certified that the **Sunrise Sr. Sec. School, Salooni** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This certificate is valid till:- **31-03-2025.**


Sub Divisional Engineer
Public Health Engg. S/Divin. No. 3
Narnaul

Signature with Seal:
Name : **Sh. Ashok Kumar**
Designation : **SUB DIVISION ENGINEER**
PUBLIC HEALTH ENGG. SUB DIVISION No. 3
NARNAUL

To
The Principal,
Sunrise Sr. Sec. School, Salooni.
TEHSIL – NARNAUL DISTT – M/GARH
HR.

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies

To,

The Principal
Sunrise sr. sec. school
Salooni.

Memo No.PHEL/NNL/..381

Date: 26/04/24

Subject:-


Testing Of Water Sample.

Ref.of your Test ID S30242,30243

Dated 19/04/2024

On the above noted subject please find herewith the water sample report of the above mentioned water samples.

This is for your kind information& necessary action please.



Sudhir Chaudhary
Authorized Signatory/QM



PUBLIC HEALTH ENGINEERING DEPARTMENT
WATER TESTING LABORATORY, NARNAUL
NARNAUL (HR)



TEST REPORT

Test Report No. : PC- 254	Issue Date:- 22.04.2024
Issued to : The Principal	Location:- Personal T/W
Your Reference No. : MHD/00452/04/2024	Collected by: - Rahul
Sample Type : Water	Sample collected date: - 19.04.2024
Name of person : Rahul	Sample received on: - 19.04.2024
Lab Job Order No. : 254	Sample Quantity: 1 Ltr.
Address : Sunrise Sr. Sec. School Salooni	Contact No.: 9467643196

S. No.	Parameter	Results	IS:10500:2012 (RA-2018)		Unit
			Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	Total Dissolved Solids (TDS)	290	500	2000	mg/L
2	Iron (Fe)	0.10	1.0	1.0	mg/L
3	Sulphate (SO ₄ ²⁻)	16	200	400	mg/L
4	Nitrate	1.0	45	45	mg/L
5	Turbidity	0.42	1	5	NTU
6	Colour	05	5	15	Hazen
7	pH	7.18	6.5	8.5	-

Continued On Next Page



PUBLIC HEALTH ENGINEERING DEPARTMENT
WATER TESTING LABORATORY
NARNAUL (HR)

PHED
Haryana
PHEDNNL7.8 F02

TEST REPORT

Test Report No. : PC- 254	Issue Date:- 22.04.2024
Issued to : The Principal	Location:- Personal T/W
Your Reference No. : MHD/00452/04/2024	Collected by: - Rahul
Sample Type : Water	Sample collected Date : - 19.04.2024
Name of person : Rahul	Sample received on: - 19.04.2024
Lab Job Order No. : 254	Sample Quantity: 1 Ltr.
Address : Sunrise Sr. Sec. School Salooni	Contact No.: 9467643196

RESULTS

S. No.	Parameter	Protocol Used	Results	IS:10500:2012(RA-2018)		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
8	Total Hardness(as CaCO_3)	APHA 23 rd edition 2340 C	90	200	600	mg/L
9	Calcium (as Ca)	APHA 23 rd edition 3500-Ca B	16.03	75	200	mg/L
10	Magnesium (as Mg)	APHA 23 rd edition 3500 Mg B	12.15	30	100	mg/L
11	Chloride (as Cl)	APHA 23 rd edition 4500 Cl- B	49.95	250	1000	mg/L
12	Total Alkalinity(as CaCO_3)	APHA 23 rd edition 2320 B	40	200	600	mg/L
13	Taste	IS:3025 Part 8	Agreeable	Agreeable	Agreeable	-
14	ODOUR	IS:3025 Part 5	Agreeable	Agreeable	Agreeable	-
15	Fluoride	APHA 23 rd edition 4500-F - D	0.20	1.0	1.5	mg/L

Opinion: The parameter tested at Sr.No. 1-15 in the test report meets the requirement of IS 10500:2012 (RA- 2018). The above water sample of sample descriptions Sunrise Sr. Sec. School chemically Fit on the Above Parameters

Notes:

- The results given above are related to the sample as received and tested in PHED Lab, Narnaul. Reliability of sample lies with the sender.
- The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- The test report can't be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Sample analyzed by: Vikas


Sudhir Chaudhary
Authorized Signatory/QM

To,

The Principal
Sunrise Sr. Sec. School
Salooni.

Memo No. 382


Date: 26/04/2024

Subject:- BACT – EXAM REPORT OF WATER SAMPLE

Person who collected sample: - Ashish Kumar
Sample collection Date :- 19/04/2024
Sample Receipt Date:- 19/04/2024

Sr. No.	Sample ID	SOURCE OF SAMPLE	NO. OF COLIFORM	No. of Feecal	RESULT
01	MHD/00451/04/2024	Personal T/W	0	0	Fit

The above sample is Fit for Human consumption.
Reliability of water sample lies with sender / collector of water sample.


Sudhir Chaudhary
Authorized Signatory/QM

Memo No:- 382

Date:- 26/04/2024

Subject : Bacteriological Examination Report of Water Sample

Sample ID:	MHD/00451/4/2024	Sample Details	Date & Time
Sample Classification:	Private	Collected By	SUNRISE SR SEC...,9467643196
Sender:	SUNRISE SR SEC SCHOOL SALOONI30242	Collection Date	19/04/2024 at 15:23
Location :-	, village salooni post barkoda tehsil narnaul	Received at lab	19/04/2024 at 17:03
Latitude :-	76.151877	Longitude :-	28.107379
		Tested at Lab	26/04/2024

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/ APHA 9221C; 2017
2	Feacal Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 1622 (1981)

Remarks :-

- * The Results Given above are related to the sample as received and tested in MAHENDRAGARH lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters.
Based on the tested parameters,the water sample is found "**POTABLE**"



SUDHIR CHOWDHARY,CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING
LABORATORYMAHENDRAGARH
email:-chemist.rewari@phedharyana.gov.in

-----End of Report-----.